

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:33 pm

PWS ID: UTAH21022 **Name:** DOCTOR CREEK CAMPGROUND
Legal Contact: USFS - FISHLAKE NATIONAL FOREST S **Rating:** Approved
MATT W VELLINGA **Rating Date:** 04/09/1996
Address: 115 E 900 N **Activity Status:** Active
RICHFIELD, UT 84701
Phone Number: 435-896-9233
City Served (Area):
County: SEVIER COUNTY
System Type: Non-community **Last Inv Update:** 02/17/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/18/2010 **Total Dsgn Cap:**
Population: 300 **Surveyor:** GARY KOBZEFF **Total Emerg Cap:**
Oper Period: 5/25 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	VELLINGA, MATT W	FOREST ENGIN	435-896-9233	435-896-9233	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	1
			1 Total Svc Connections

Storage

Total Storage: 18,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	16000 GALLON TANK	Ground	16,000 GAL	Concrete		A	NO
ST002	STORAGE FACILITY ST002	Ground	2,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	DOCTOR CREEK CHLORINATOR		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	DOCTOR CREEK CG BOOSTER	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	DOCTOR CREEK SPRING	Active	SP				Yes	GW	Seasonal	5/25 to 9/30	

**Reports measured flow for wells, approved design capacity for all other sources.*